

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	19-08-2026 12:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	19-08-2026 12:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	180 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Jammu & Kashmir
विभाग का नाम / Department Name	Power Development Department Jammu And Kashmir
संगठन का नाम / Organisation Name	N/a
कार्यालय का नाम / Office Name	Direction Officer
शिकायत निवारण के संपर्क विवरण / Contact details of Grievance redressal	HOD Email id : cemre-jammu@jk.gov.in Buyer Email id: gautam67@gmail.com
कुल मात्रा / Total Quantity	4
वस्तु श्रेणी / Item Category	Power Transformer, Oil immersed type (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	88 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	88 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष / Years of Past Experience Required for same/similar service	3 Year (s)
टर्नओवर पात्रता मानदंड / Turnover eligibility criteria	To be verified by the buyer at the time of technical evaluation
टर्नओवर के लिए एमएसई को छूट प्राप्त है / MSE Relaxation for Turnover	Yes Partial Turn over value - 88 (in lakhs)
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years of Experience and Turnover	No

बिड विवरण/Bid Details	
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC),Additional Doc 3 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	3
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	3
विगत प्रदर्शन /Past Performance	20 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य / Estimated Bid Value	29264000
Payment Timelines	Payments shall be made to the Seller within 45 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	585000

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	60

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c). ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

Chief Engineer, P&P wing
Office of the Chief Engineer, Planning and Procurement wing JPDCL, Jammu
(Chief Engineer)

UIN Number NCTGC2415P**विभाजन/Splitting**

विभाजन/Splitting Applied	Yes
बोलीदाताओं की अधिकतम संख्या, जिनके बीच ऑर्डर विभाजित किया जा सकता है। / Maximum No. Of Bidders Amongst Which Order May Be Split	2
विभाजन मानदंड इस बात पर आधारित है कि कौन सी क्वांटिटी को वितरित किया जाएगा / Split Criteria based on which quantity will be distributed	As per manual for procurement of Goods

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	No
---	----

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

1. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
2. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
4. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.
6. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 20% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.
7. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:
 - i. If number of technically qualified bidders are only 2 or 3.
 - ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
 - iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
 - iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
 - v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

Pre Bid Detail(s)

मूल्य भिन्नता खंड दस्तावेज़/Pre-Bid Date and Time	प्री-बिड स्थान/Pre-Bid Venue
08-08-2026 14:00:00	Office of the Chief Engineer, P and P wing JPDCL, Jammu

Power Transformer, Oil Immersed Type (4 pieces)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
RATING	Rated Voltage - HV (in KV)	11, 22, 33, 66, 132, 220, 400, 765, 3.3, 6.6
	Rated Voltage - LV (in kV)	0.23, 0.415, 6.6, 11, 33, 66, 132, 220, 3.3
	Maximum system voltage - HV (in kV)	12, 24, 36, 72.5, 145, 245, 420, 800, 3.6, 7.2
	Maximum system voltage - LV (in kV)	0.25, 0.46, 7.2, 12, 36, 72.5, 145, 245
	Rated power (in MVA)	5, 6.3, 8, 10, 12.5, 16, 20, 32, 40, 6.5, 30, 30.4, 33.3, 42, 50, 63, 66.7, 80, 100, 150, 160, 166.7, 200, 250, 315, 500, 1, 3.15
	No. of Phase	1, 3, 3 Ph. 2 Winding
GENERIC	Conformity of the specification	IS:2026 (Part 1) : 2011 latest, IS:2026 (Part 1) : 2011 latest and as per Annexure - A attached for Coal India, as per IEC:60076:2011 latest
	Designed for	Indoor, Outdoor
	Installation, Testing and Demonstration	Yes, No, Yes. Including civil works related to installation and commissioning of transformer
INSULATION LEVEL	Insulation Levels, Dielectric Tests and External Clearances in Air	as per IS: 2026 Part 3: 2009 latest, as per IEC:60076:2011 latest
	Standard rated short duration power-frequency withstand voltage, r.m.s value (in kV)	10, 20, 28, 50, 70, 140, 150, 275 (for 132 KV), 70 (for 33 KV), 38, 95, 250, 450, 550, 650, 750, 850, 950, 1050, 1175, 1300, 1425, 1550, 1675, 1800, 1950, 2100, 230, 275, 325, 395, 460, 510, 570, 630
	Standard rated lightning impulse withstand voltage (in kV, peak)	20, 40, 60, 75, 95, 125, 145, 170, 325, 650 (for 132 KV), 170 (for 33 KV), 250, 450, 550, 650, 750, 850, 950, 1050, 1175, 1300, 1425, 1550, 1675, 1800, 1950, 2100
WINDING	Winding insulation	Class A
	Connection symbol	Dyn 11, Star / Star (YNyn0), Not applicable, HV- Star, Delta LV- star, Delta
	Terminals of all windings	Out of the tank through bushings for external connections, With cable box
	Material of barrier insulation including spacers	High Density Press board
TAP CHANGER	Type of Tap Changer	Off Circuit, On Load, NA
	Winding tapped at	HV, NA, LV
	No. of tapplings (in Nos.)	17, 9, NA, 16 (Excluding normal), 5

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Range of tappings	+10% to -10% in equal seps of 1.25%, +5% to-15% in equal seps of 1.25%, +5% to-5% in equal seps of 7.5%, NA, Tap range : - 15% to + 5% Rate of steps : 1.25 %of 132kv, (?) 9 % to (+) 3%
CONSTRUCTION	Material of core	CRGO (ColdRolled GrainOriented steel), CRGO silicon alloy steel
	The maximum flux density in any part of the cores and yoke at normal voltage and frequency	< 1.5 Tesla, < 1.7 Tesla, < 1.9 Tesla, < 1.6 Tesla
	Type of cooling	ONAN, ONAN cooling 80% for 16 MVA,, ONAF cooling 100% for 20 MVA, ONAN cooling 80% for 32 MVA,, ONAF cooling 100% for 40 MVA, ONAF, OFAF, OFDF, OFWF
	Transformer filled with oil	Yes, No
	Method of system earthing	LV Winding: Solidly earthed, HV connections : Star with neutral solidly earthed, LV connections : Star with neutral solidly earthed, Neutral of HV,LV solidly earthed
	Type of oil preservation system	Freely breathing type, Conservator type, Diaphragm type, Inert Gas Pressure type, Sealed tank type
	Temperature rise limit - Top oil measured by thermometer	< 40 deg. C, < 45 deg. C, < 50 deg. C
	Temperature rise limit - Winding temperature by resistance	< 45 deg. C, < 55 deg. C
	Percentage of impedance voltage on normal tap and MVA base at 75 deg. C corresponding to HV/ LV rating (in %)	6.25, 7.15, 8.35, 10, 12.5, 13, 14, 15
	No Load Losses (Fixed Loss) , Maximum (in KW)	3, 4, 4.6, 5.5, 7, 7.5, 16, 25, 9, 10, 12, 14, 18, 30, 35, 45, 60, 70, 75, 90
	Load losses at 75°C, Maximum (in KW)	16, 23, 36, 40, 50, 65, 130, 185, 80, 90, 95, 110, 125, 140, 200, 245, 260, 400, 440, 450, 500
	Minium Creepage Distance (in mm)	HV-900 mm, LV-300 mm, 25 mm per KV, 31 mm per KV, 35 mm per KV
TRANFORMER TANK	Transformer tank construction shall conform in all respect to	Clause 15 of IS 1180(Part1):2014., as per Annexure-A attached for Coal India, Bell shaped, Conventional
	Transformer tank top cover	Detachable with bolted flanged gasket joint, as per Annexure-A attached for Coal India, Bolted, Welded
	The surface of the cover	Suitable sloped, as per Annexure-A attached for Coal India, Flat
	The transformer tank	supported on steel structure, as per Annexure-A attached for Coal India

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
ADD ON ITEMS	Oil conservator tank (in Nos.)	1, 0
	Buchholz Relay	1, 0
	Oil Temperature Indicator (OTI) (in Nos.)	1, 0, 1 No. For Local & remote winding with contacts
	Winding Temperature indicator (WTI) (in Nos.)	1, 0, 2 Nos. Per phase, 1 No. For Local & remote winding with contacts
	Pressure Relief Device (in Nos.)	1, 0, 2, 3
	Oil Level Indicator (in Nos.)	1, 0
	Silica Gel Breather with Silica Gel (in Nos.)	1, 0, 2, 3
	Drain Valve on transformer tank (in Nos.)	1, 0, 2
	Filter Valve on transformer tank (in Nos.)	1, 2, 0
	Oil sampling valve on transformer tank (in Nos.)	1, 0, 2
	Air release plug (in Nos.)	150 mm dia, 1 No., NA, 15 mm NB 1 no.
	Lifting eyes or lugs for the top cover, core and coils and for the complete transformer	Yes, No
	Tank earthing terminals with associated nuts and bolts for connections to grounding strip	2 sets, 0
	HV Bushings according to highest system voltage (in Nos.)	2 (Porcelain), 3 (Porcelain), 0, 1 No. Porcelain with metal parts and gaskets
	LV Bushings according to highest system voltage (in Nos.)	2 (Porcelain), 3 (Porcelain), 0, 1 No. Porcelain with metal parts and gaskets
	Terminal arrangement: for HV/LV bushings with arcing horns	Yes, No
	Suitable terminal connector for HV & LV terminal for holding Conductor	Yes. Suitable for Panther type, No
	Bus Bars	Copper at LV side, No
	Cable termination box	1 No. at LV side, No, 1 No. at HV side and 1 No. at LV side
	Arrangement for Auxiliary supply voltage for	For Alarm, For Relays, NA

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Marshalling box with required glands, locks, glass door, terminal Board, heater with switch, illumination lamp with switch etc to accommodate temperature indicators terminal blocks etc	1, 0
	Ingress protection for Marshalling Box	IP 55, IP 54
	Padlocks and locking key arrangements for	Mrashalling box, Valves, NA
	Foundation bolts for wheel locking devices of Transformer	Yes, No
	Bi-metallic terminal connector/ clamp/ washers suitable for fixing to bushing terminals	Yes, No
	Other requirements	Air release plug, 1 No., Rating Plate, NA, 1 No. Neutral Bushing, Metal parts for Bushings, Gaskets for Bushings, Magnetic oil level gauge: 1 No., Magnetic Oil Level Gauge with Low oil level alarm contacts, 1 No. Cooler fan with motor, HV & LV neutral : brought out on separate bushing, 1 No. Dial type thermometer, Thermometer: Maximum reading pointer, Thermometer: adjustable, Thermometer: Potential free contacts for alarm and trip for top oil temperature ., Additional pockets for mercury-in-glass thermometer for measuring oil and winding temperature, Explosion/ relief vent with double diaphragm equalizer connection, Diagram plates, Terminal marking plate, Identification marking plate, Approved Pressure Relief Device for Rapid Release of Pressure, Under carriage with jacking pads, Under carriage with hauling holes / hook, Supervisory alarm for oil temperature indicator, Supervisory trip contacts for oil temperature indicator, Supervisory alarm for gas operated double float relay, Supervisory trip contacts for gas operated double float relay, Supervisory alarm contacts for oil level indicator, Inspection cover, Oil filling hole and cap, Thermometer for Oil Temp Indicator 150mm, Dial Type.
	Agreed for unloading of transformer at site	Yes, No
SPECIAL TEST	Agreed to furnish special test reports as per	Cl.10.1.3 of IS:2026 (Part 1) latest, NA
	Test reports for dielectric special tests	Yes, No

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Test report for determination of capacitances winding to earth, and between windings	Yes, No
	Test report for determination of transient voltage transfer characteristics	Yes, No
	Test reports for measurement of zero sequence impedance (s) on three phase transformers	Yes, No
	Test report for determination of sound levels	Yes, No
	Test report for measurement of harmonics of the no load current	Yes, No, Yes. Including Contact Resistance Test (<2 miliohm)
	Test report for measurement of the power taken by the fan and oil pump motors	Yes, No, Yes. Including Measurement of Impedance voltage at highest rated and lowest voltage taps
	Test report for measurement of insulation resistance to earth of the windings and or measurement of dissipation factor of the insulation system capacitances	Yes, No, Yes. Including Ratio and high voltage magnetisation current test.
CERTIFICATIONS	Agreed for stage inspection as and when required by buyer / consingee	Yes as per buyer requirements, No
	Agreed to furnish Guaranteed Technical Particulars (GTP) and complete drawings of Power Transformer as and when required by buyer / consignee	Yes, No
	Agreed to furnish routine test reports to buyer / consingee on demand	as per Cl.10.1.1 of IS:2026 (Part 1) latest, No, as per Annexure-A attached for Coal India
	Availability of Type test report from Central Government/NABL/ILAC accridiated laoratory to prove conformity of the specification	Yes, No, as per Annexure-A attached for Coal India

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Agreed to furnish routine and type tet reports for porcelain bushings	Yes, No

Additional Specification Parameters - Power Transformer, Oil Immersed Type (4 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
All the specifications and parameters shall be as per SBD and GTP	All the specifications and parameters shall be as per SBD and GTP

* Bidders offering must also comply with the additional specification parameters mentioned above.

परिषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परिषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Manjeet Singh	180012,Office of the Executive Engineer JPDCL Eelctric Central Store Division Jammu Rail Head Complex Jammu	4	120

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Generic

After award of contract – Successful Bidder shall have to get Detailed Design Drawings approved from buyer before starting fabrication. Successful Bidder shall submit Detailed Design Drawings for Buyer's approval, within 7 days of award of contract. Buyer shall, either approve the drawings or will provide complete list of modification required in the drawings within 5 days. Seller shall be required to ensure supply as per approved Drawings with modifications as communicated by Buyer. If there is delay from buyer side in approval of drawing– the delivery period shall be refixed without LD for the period of delay

in approval of Drawing.

3. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

Payment will be made on availability of funds. Since the material is purchased under CAPEX budget, funding of which is released in phased manner by the Government, as such the payment shall be released accordingly in the financial year (applicable to both MSME and non MSME units)

4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer, is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- **All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and**
- **All operative provisions of the erstwhile Labour Laws until their complete substitution.**

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्यवाई का आधार होगा।/In terms

of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---